



400 captain neville drive waterbury, ct. 06075 1-800-543-6163 support@eemaxinc.com

PARALLEL WITH STORAGE TANK

DRAWING IS A RECOMMENDATION ONLY THIS IS NOT AN ENGINEERING DRAWING; IT IS INTENDED ONLY AS A GUIDE AND NOT AS A REPLACEMENT FOR PROFESSIONAL ENGINEERING PROJECT DRAWINGS. THIS DRAWING IS NOT INTENDED TO DESCRIBE A COMPLET SYSTEM. IT IS UP TO THE CONTRACTOR OR ENGINEER TO DETERMINE THE NECESSARY COMPONENTS AND CONFIGURATION OF THE PARTICULAR SYSTEM TO BE INSTALLED. THE DRAWING DDES NOT IMPLY COMPLIANCE WITH LOCAL BUILDING CODE REQUIREMENTS IT IS THE RESPONSIBILITY OF THE ENGINEER OR CONTRACTOR TO ENSURE THAT THE INSTALLATION IS IN ACCORDANCE WITH ALL LOCAL BUILDING CODES. COMFER WITH LOCAL BUILDING OFFICIALS BEFORE INSTALLATION.

NOTES:

MAIN CIRCULATOR SIZE TO BE DETERMINED

STORAGE TANK PROVIDED BY OTHERS. 80 GALLON IS PREFERRED FOR HIGH VOLUME DEMANDS OF 25 GPM AND ABOVE