



Heat Transfer Products Group, LLC  
 A Division of Rheem Manufacturing  
 201 Thomas French Drive  
 Scottsboro, Alabama 35769

Date: 23 November 2022

**SUBJECT: Wind Load Analysis of HTPG ½ to 6HP Multi-Refrigerant Air Cooled Condensing Units**

The following wind load analysis applies to all HTPG ½ to 6 HP Multi-Refrigerant Air Cooled Condensing Units using the following nomenclature description:

<b>R</b>	<b>F</b>	<b>O</b>	<b>500</b>	<b>M</b>	<b>48</b>	<b>C</b>	<b>A</b>
1	2	3	4	5	6	7	8

The listings below are the positions for the model with a brief explanation

- 1 **Branding:** R Russell W Witt K Kramer C ColdZone ? Other brands may use single letter code or asterisk “\*\*”
- 2 **Condenser and Control Type:** B No Flooded Condenser Control ( Indoor or Warm Climate Outdoor) F Flooded Condenser Control (Outdoor)  
W Water Cooled Condenser R Remote Compressor Unit S Sierra (Special Condenser Outdoor) 3
- 3 **Compressor Type:** H Hermetic S Semi-hermetic O Scroll
- 4 **Nominal Size:** XXX Three numbers roughly equal to compressor horsepower times 100
- 5 **Temperature Range:** L Low Temp M Medium Temp E Extended Temp
- 6 **Refrigerant Type:** 44 R404A 47 R407C 4A R407A 48 R448A or R449A 4S Used when compressor is rated for all refrigerants in this list
- 7 **Voltage/Phase/Frequency Code:** C 230/1/60 D 208-230/1/60 E 208-230/3/60 G 460/3/60 V 208/3/60 W 230/3/60 Q 575/3/60 8  
**Revision Code:** Starting with letter A

The wind load analysis has determined these multi-refrigerant air cooled condensing units are in accordance with ASCE/SEI 7-16, Florida Building Code Seventh Edition (2020) for the following location:

**Installation location:** Miami – Dade County, Florida

<b>Roof Mounting Requirement</b>		
Corner Attachment Point	Tension, lbs. Uplift	Shear, lbs. Horizontal Load
1	620	450
2	620	450
3	620	450
4	620	450

Using a roof curb to install these condensing units requires a metal mounting surface with stand details to be provided by the selected mechanical contractor at the job site.